



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

NOTICE OF ACCEPTANCE (NOA)

www.miamidade.gov/economy

Wausau Tile, Inc.
PO Box 1520
Wausau, WI 54402-1520

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Terra Stand Screw Top Pedestal with Lok-Down

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.

The submitted documentation was reviewed by Gaspar J Rodriguez.



NOA No.: 15-1222.02
Expiration Date: 09/15/21
Approval Date: 09/15/16
Page 1 of 3

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Pedestal Base for Rooftop Pavers
Materials: Polypropylene

SCOPE:

This approves **Terra Stand Screw Top Pedestal with Lok-Down**, as manufactured Wausau Tile, Inc., as described in this Notice of Acceptance. The use of this acceptance is limited to those roof assemblies where Terra Stand Screw Top Pedestal with Lok-Down, is specifically listed as an accepted component.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Lok-Down Terra Stand	Base : 7" x 7" Height : 2½" to 22"	TAS 110	Adjustable pedestal that screws up, down and tilts from side to side to provide a level surface for rooftop paver installation.
Lok-Down Base Plate	7" x 7"	TAS 110	High impact copolymer polypropylene fastened to roof deck.
Lok-Down Top Plate	7" x 7"	TAS 110	High impact copolymer polypropylene used to fasten paver to stand.
Lok-Down Paver	24" x 24" x 2"	ASTM C140	Average compressive strength shall not be less than 8,000 psi with no individual unit less than 7,000 psi.

MANUFACTURING LOCATION:

1. Clintonville, WI

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Intertek-ATI	F0856.01-106-18	ASTM G155	05/10/16
	F0856.01-106-18	ASTM D638	05/10/16
	F0856.01-106-18	ASTM D1929	05/10/16
	F0856.01-106-18	ASTM D2843	05/10/16
	F0856.01-106-18	ASTM D635	05/10/16




NOA No.: 15-1222.02
Expiration Date: 09/15/21
Approval Date: 09/15/16
Page 2 of 3

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance.
2. The products listed herein are components of roof assemblies. Terra Stand Screw Top Pedestal may be used with any approved roof assembly listing Terra Stand Screw Top Pedestal as a component part of assembly in the Notice of Acceptance. If Terra Stand Screw Top Pedestal is not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
3. All flashings must be in compliance with a Roof Assembly Notice of Acceptance and applicable Building Code.
4. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
5. All products listed herein shall bear the imprint or identifiable marking of the manufacturer's name or logo, city and state of manufacturing facility and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.

MIAMI-DADE COUNTY
APPROVED



Details of Terra-Stand Pedestal System

END OF THIS ACCEPTANCE

MIAMI-DADE COUNTY
APPROVED

NOA No.: 15-1222.02
Expiration Date: 09/15/21
Approval Date: 09/15/16
Page 3 of 3